

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7270-0067:156 Page 1 of 1

CATEGORY: Heat Detector

LISTEE: Siemens Building Technologies Inc., *Fire Safety Div., 8 Fernwood Rd, Florham Park NJ 07932
Contact: Peter Pawchak (973) 593-2662 Fax (973) 593-6652

DESIGN: Models DT-135R, DT-200R, DT135F and DT200F. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or Cerberus Pyrotronics, model number, electrical rating and UL label.

APPROVAL: Listed as system heat detectors for use with any separately listed compatible control units.

XLF: 7270-0061:005

*Rev. 10-26-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

OCTOBER 26, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager